

SERTIFIKAT O KONTROLISANJU INSPECTION CERTIFICATE

Broj / Number: C 2110

Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser:

HL Hutterer & Lechner GmbH, 2325 Himberg, Brauhausgasse 3-5, Austria

preduzeto je/
set to:

kontrolisanje postojećeg proizvoda / *inspection of existing product*

u vezi sa Izveštajem /
in relation to Inspection report:

Micro Med GmbH 421-2017, C 1610

sa priloženim dokumentima /
with attached documents:

- Izvod iz kataloga proizvoda /
Catalogue pages of product ;

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object :

UGRADNI SIFON ZA KONDENZOVANU VODU /
DRAIN BODY FOR IN-WALL SIPHON FOR CONDENSATE WATER

proizvođač /
manufacturer:

HL Hutterer & Lechner GmbH, 2325 Himberg, Brauhausgasse 3-5, Austria

oznaka modela /
mark of the model :

HL138

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements described in:

referentnom dokumentu /
reference document :

DIN 19541

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical inspection until the date :

26.05.2026. god.

izdat od / issued by :

UKOVODILAC CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER

mesto, datum / place, date

Beograd, 26.05.2021. god

M.P. / S.P.

Kristina Petković, dipl. maš. inž.

Ime, Prezime / Name, Surname

Inspection certificate

Sertifikat o kontrolisanju

SERTIFIKAT O KONTROLISANJU **INSPECTION CERTIFICATE**

Broj / Number: **C 2110**

Strana / Page: **2/2**

Prilog A / Annex A

Pregled proizvoda u okviru modela / *Product review of the model*

oznaka modela / mark of the model:	dimenzije* / dimensions: d _s (mm)	težina / weight: (g)	kratak opis / short description:
HL138	DN 32	280	- ugradni sifon za kondenzovanu vodu predviđen za ugradnju u klimatizacionim, grejnim i ventilacionim sistemima gde postoji potreba za odvođenjem kondenzovane vode, <i>drain body for in-wall siphon for condensate water predicted for integration in air-conditioning, ventilation and heating systems, where condensate water drainage system is to be implemented,</i> - izrađen od PP/ABS (polipropilen), <i>made of PP/ABS (polypropylene),</i> - kapacitet - : 0,15 l/s./ <i>capacity - : 0,15 l/s.</i>

* - dimenzija izlaznog priključka

Inspection certificate

Sertifikat o kontrolisanju