

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: **C 2106**

Strana / Page: **1/2**

Na zahtev naručioca /
By the request of purchaser: **HL Hutterer & Lechner GmbH, 2325 Himberg, Brauhausgasse 3-5, Austria**

preduzeto je /
set to: **kontrolisanje postojećeg proizvoda / inspection of existing product**

u vezi sa Izveštajem /
in relation to Inspection report: **TUV Rheinland LGA Nr.7311040-11z**

sa priloženim dokumentima /
with attached documents: **- Izvod iz prospekt proizvoda / Catalogue pages of product ;**

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object : **KROVNI SIGURNOSNI SLIVNICI / FLAT ROOF SAFETY DRAINS**

proizvođač /
manufacturer: **HL Hutterer & Lechner GmbH, 2325 Himberg, Brauhausgasse 3-5, Austria**

oznaka modela /
mark of the model : **HL62Safe - /, H, P, F, HL64Safe - /, H, P, F**

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements described in:

referentnom dokumentu /
reference document : **SRPS EN 1253-1 :2016**

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical
inspection until the date :

26.05.2026. god.

izdat od / issued by :

UKOVODILAC CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER

mesto, datum / place, date:

Beograd, 26.05.2021. god.



Kristina Petković, dipl. maš. inž.

Ime, Prezime / Name, Surname

SERTIFIKAT O KONTROLISANJU

INSPECTION CERTIFICATE

Broj / Number: C 2106

Strana / Page: 2/2

Prilog A / Annex A

Pregled proizvoda u okviru modela / Product review of the model

oznaka modela / mark of the model:	dimenzije* / dimensions: d _s (mm)	težina / weight: (g)	kratak opis / short description:
HL62Safe (/ , H, P, F)	DN 75/110/125 /160	2814 - 3634	– krovni sigurnosni slivnik u izvedbi sa ili bez samoregulišućeg grejača snage 10 - 30 W, sa vertikalnim odvodom i podesivnim ulivnim elementom po visini./ <i>roof safetydrains with or without self-regulated heater 10 - 30 W, with vertical drainage and height adjustable intake element,</i> – sa (HL62SafeH) ili bez (HL62Safe - / , P i F) bitumenske kragne./ <i>with (HL62SafeH) or without (HL62Safe - / , P and F) bitumen collar,</i> – izrađen od PP (polipropilen, HL62Safe - / , H, i F) i PVC (H62SafeP), kućište slivnika toplotno izolovano./ <i>made of PP (polypropilene, HL62Safe - / , H, and F) and PVC (H62SafeP), insulated drain body,</i> – kapaciteti - u zavisnosti od vodenog stuba , vrednosti date u kataloškim stranicama./ <i>capacities - according to the waterheight, values given in catalogue pages.</i>
HL64Safe (/ , H, P, F)	DN 75/110	1639 - 2095	– krovni sigurnosni slivnik u izvedbi sa ili bez samoregulišućeg grejača snage 10 - 30 W, sa horizontalnim odvodom i podesivnim ulivnim elementom po visini./ <i>roof safetydrains with or without self-regulated heater 10 - 30 W, with horizontal drainage and height adjustable intake element,</i> – sa (HL64SafeH) ili bez (HL64Safe - / , P i F) bitumenske kragne./ <i>with (HL64SafeH) or without (HL64Safe - / , P and F) bitumen collar,</i> – izrađen od PP (polipropilen, HL62Safe - / , H, i F) i PP+PVC (H62SafeP), kućište slivnika toplotno izolovano./ <i>made of PP (polypropilene, HL62Safe - / , H, and F) and PVC (H62SafeP), insulated drain body,</i> – kapaciteti - u zavisnosti od vodenog stuba , vrednosti date u kataloškim stranicama./ <i>capacities - according to the waterheight, values given in catalogue pages.</i>

* - dimenzija izlaznog priključka / dimension of outlet socket

Inspection certificate

Sertifikat o kontrolisanju